

**This document is for reference only. Specific fire safety requirements will be issued subject to the result of on-site assessment.**

**本文件只供參考。詳細的消防安全規定會視乎現場評估的結果而另行發出。**

**Sample 2**

**範本 2**



**FIRE SAFETY REQUIREMENTS FOR TIMBER STORE ON GROUND FLOOR  
OF NON-INDUSTRIAL BUILDINGS**

設於非工業樓宇地下的木料倉的消防安全規定

1. Timber store shall be constructed and maintained in good and substantial repair and clean condition to the satisfaction of the Authority.  
木料倉的建造及保養，必須保持在妥善、維修充足及清潔乾淨的狀況，以令消防處滿意。
2. Neither open fires nor any cooking shall be permitted in any timber store.  
木料倉內不得有明火；亦不得在倉內煮食。
3. No person, except watchman only not exceeding two in number, shall dwell in any timber store.  
任何人均不得在倉內居住，看守員除外，但不得超過兩人。
4. The licensee of any timber store shall install such fire service installations and equipment as required by the Authority and maintain them in efficient working order.  
木料倉持牌人必須依照消防處的規定裝設消防裝置或設備，並經常保持其操作性能良好。

**This document is for reference only. Specific fire safety requirements will be issued subject to the result of on-site assessment.**

**本文件只供參考。詳細的消防安全規定會視乎現場評估的結果而另行發出。**

**This document is for reference only. Specific fire safety requirements will be issued subject to the result of on-site assessment.**

**本文件只供參考。詳細的消防安全規定會視乎現場評估的結果而另行發出。**

**Sample 2**

**範本 2**

5. Sufficient 'NO SMOKING' signs in 120mm English letters and Chinese characters shall be prominently displayed.  
須將足夠數量的中英文“不准吸烟”告示，懸掛於當眼位置，字體大小應為 120 毫米。
6. All timber shall be kept inside the store.  
所有木料必須存放於倉內。
7. No electric machinery shall be installed.  
不得設置電動機器。
8. Total amount of timber stored shall not exceed half of the cubic volume of the store.  
貯存的木料總數量，不得超過該木料倉立方容積的一半。
9. \_\_\_\_\_ 9-litre water type fire extinguisher(s) of approved models shall be provided.  
須設置認可類型的九公升裝水式滅火筒 \_\_\_\_\_ 具。
10. All exits shall be kept free from obstruction.  
所有出口必須保持暢通無阻。
11. Except for timber store located in industrial building, no industrial process will be allowed. Premises shall only be used for storage/retail of timber only.  
設於工業樓宇以外地點的木料倉，不得進行任何工業工序。該處所只可作貯存／零售木料的用途。

**This document is for reference only. Specific fire safety requirements will be issued subject to the result of on-site assessment.**

**本文件只供參考。詳細的消防安全規定會視乎現場評估的結果而另行發出。**