

**This document is for reference only. Specific fire safety requirements will be issued subject to the result of on-site assessment.**

**本文件只供參考。詳細的消防安全規定會視乎現場評估的結果而另行發出。**

**Sample 3**

**範本 3**



**FIRE SAFETY REQUIREMENTS FOR TIMBER STORE ON OPEN GROUND**

**設於露天地方的木料倉的消防安全規定**

1. Timber store shall be constructed and maintained in good and substantial repair and clean condition to the satisfaction of the Authority.  
木料倉的建造及保養，必須保持在妥善、維修充足及清潔乾淨的狀況，以令消防處滿意。
2. Neither open fires nor any cooking shall be permitted in any timber store.  
木料倉內不得有明火；亦不得在倉內煮食。
3. No person, except watchman only not exceeding two in number, shall dwell in any timber store.  
任何人均不得在倉內居住，看守員除外，但不得超過兩人。
4. The licensee of any timber store shall install such fire service installations and equipment as required by the Authority and maintain them in efficient working order.  
木料倉持牌人必須依照消防處的規定裝設消防裝置或設備，並經常保持其操作性能良好。

**This document is for reference only. Specific fire safety requirements will be issued subject to the result of on-site assessment.**

**本文件只供參考。詳細的消防安全規定會視乎現場評估的結果而另行發出。**

**This document is for reference only. Specific fire safety requirements will be issued subject to the result of on-site assessment.**

**本文件只供參考。詳細的消防安全規定會視乎現場評估的結果而另行發出。**

**Sample 3**

**範本 3**

5. Sufficient 'NO SMOKING' signs in 120mm English letters and Chinese characters shall be prominently displayed.  
須將足夠數量的中英文“不准吸烟”告示，懸掛於當眼位置，字體大小應為 120 毫米。
6. Where electric machinery is installed, the Commissioner for Labour shall be informed.  
如設有電動機器，必須向勞工處處長呈報。
7. The timber store shall be surrounded by a fence of not less than 2m in height and constructed of non-combustible materials where the store is within 15m of any building.  
如木料倉所在位置與任何建築物相距不足十五米，應採用不可燃物料建造不低過兩米的圍欄，以環繞倉庫範圍。
8. \_\_\_\_\_9-litre water type fire extinguisher(s) of approved models shall be provided.  
須設置認可類型的九公升裝水式滅火筒 \_\_\_\_\_ 具。
9. All exits shall be kept free from obstruction.  
所有出口必須保持暢通無阻。
10. All structures erected within the timber store shall be approved by the Buildings Department and constructed of non-combustible materials.  
木料倉範圍內的全部建築物，必須得到屋宇署核准，並以不可燃物料建造。

**This document is for reference only. Specific fire safety requirements will be issued subject to the result of on-site assessment.**

**本文件只供參考。詳細的消防安全規定會視乎現場評估的結果而另行發出。**