

消防處  
牌照及審批總區

香港九龍尖沙咀東部康莊道1號5樓  
消防總部大廈



FIRE SERVICES DEPARTMENT  
LICENSING & CERTIFICATION COMMAND

5/F, FIRE SERVICES HEADQUARTERS BUILDING,  
No. 1 Hong Chong Road, Tsim Sha Tsui East,  
Kowloon, Hong Kong

本處檔號 Our Ref.: (120) in FPB 314/43  
來函檔號 Your Ref.:  
圖文傳真 Fax: 852-2723 2197  
電話 Tel. No. 852-2733 7746  
電子郵件 E-mail: lcpolic2@hkfsd.gov.hk

10 December 2009

To: All Registered Fire Service Installation Contractors

**REMINDER: Maintenance of Fire Service Installations and Equipment**

This serves to remind all Registered Fire Service Installation Contractors (RFSIC) on the proper maintenance of fire service installations and equipment (FSI). You may be aware of a recent incident involving a compressed gas cylinder of an FSI which caused fatal and serious injuries to the workers undertaking maintenance work. In this regard, the statutory requirements for examination, testing and certification of gas cylinders used as FSI as provided in the relevant legislation are summarized and tabulated below for your reference:

Installation / Equipment	Type of Maintenance Work	Person Authorized by FSD for maintenance work
FSI (other than portable equipment)	Annual Inspection	RFSIC
	Maintenance / Repair	Class 1 <i>and/or</i> Class 2
Pressure cylinder* of an FSI [*Required to be approved by FSD under r. 64 of the Dangerous Goods (General) Regulations, Cap. 295B]	Hydraulic Pressure Test every 5 years	#Approved Person for examination, testing and certification of gas cylinders
	Charging	Person holding a licence for the manufacture of relevant dangerous goods
Portable Equipment [Required to be approved under r. 3 of the Fire Service (Installations and Equipment) Regulations, Cap. 95B]	Annual Inspection	RFSIC Class 3
	Hydraulic Pressure Test every 5 years	
	Refilling of extinguishing agent and/ or charging of fire extinguishers <i>other than</i> CO <sub>2</sub> gas and clean agent fire extinguishers	
	Charging of CO <sub>2</sub> gas and clean agent fire extinguishers	Supplier of portable equipment (Person holding a licence for the manufacture of relevant dangerous goods)

\* For list of Approved Persons for examination, testing and certification of gas cylinders, please refer to FSD webpage: [http://www.hkfsd.gov.hk/home/eng/source/approved\\_person\\_66\\_67\\_DGO.pdf](http://www.hkfsd.gov.hk/home/eng/source/approved_person_66_67_DGO.pdf)

In handling pressure cylinders, manufacturer's instructions and guidelines should be adhered to under all circumstances.

Please contact this Department at 27337827 or 27337557 should you need further information.

Yours faithfully,

(Robert LAU)

for Director of Fire Services