

消 防 處
牌 照 及 審 批 總 區
香 港 九 龍 尖 沙 咀 東 康 莊 道 1 號 5 樓
消 防 總 部 大 廈



FIRE SERVICES DEPARTMENT
LICENSING AND CERTIFICATION COMMAND
5/F, FIRE SERVICES HEADQUARTERS BUILDING,
No.1 Hong Chong Road, Tsim Sha Tsui East,
Kowloon, Hong Kong

本處檔號 OUR REF.: (20) in L/M (3) in FSD LCHQ (G) 6-20/1 Pt. 2
來函檔號 YOUR REF.:
圖文傳真 FAX NO.: (852) 2723 2197
電 話 TEL NO.: (852) 2733 7744
電子郵件 E-mail : <lcplc2@hkfsd.gov.hk>

16 May 2016

To: The Association of
Registered Fire Service Installation Contractors of
Hong Kong Ltd.

Dear Sir/Madam,


Fire Resisting Cable for Fire Services Installations

This serves to remind all Registered Fire Service Installations Contractors (RFSIC) that you are required to observe the requirements of fire resisting cables for use in fire service installations (FSI) as stipulated in paragraph 5.15 of Part V of the Code of Practice for Minimum Fire Service Installations and Equipment (CoP) whenever fire resisting cables are used in FSI.

With a view to ensuring that fire resisting cables used in FSI are of the required product standard and quality, you are advised to purchase such cables from authorised agents or reputable suppliers as far as practicable. It is the duty of RFSIC to ensure all fire resisting cables do conform to the standards specified in the CoP before carrying out any installation work. Failure in observance of the CoP may result in disciplinary action.

Please feel free to contact Engineer (FSI) at 2733 7563 or Senior Station Officer (Investigation & Research) at 2733 7827 should you need further information.

Yours faithfully,



(Robert LAU)

for Director of Fire Services