

LIST OF PRODUCT APPROVED FOR USE IN VENTILATING SYSTEMS

Ventilation Systems Group of FIRE SERVICES DEPARTMENT

Note (1) : For details of the acceptance criteria / conditions , please refer to the FSD approval letter(s) issued to the manufacturer / authorized supplier(s) of the products

Note (2) : Please refer to FSD Circular Letter No. 1/2024 for guidance for application for approval of Fusible Link and Electrostatic Filter or Precipitator products. If the product has been listed and published by a Product Certification Body (PCB) and Product Certification, it is deemed to be accepted by the FSD subject to such product being in conforming with all local relevant local requirements on product specification and its application in ventilating systems. As stipulated under Chapter 123J - Building (Ventilating Systems) Regulations and Chapter 132CE - Ventilation of Scheduled Premises Regulation, fusible link and electrostatic filter or precipitator shall be of a type approved by the Director of Fire Services. In this connection, application for FSD approval on all fusible link and electrostatic filter or precipitator for use in ventilating systems is required.

TYPE	BRAND NAME / MODELS / DESCRIPTION	MANUFACTURER / AUTHORIZED SUPPLIER	FSD ACCEPTANCE DATE	DATE TO REVIEW (Subject to Renewal)	Remarks
(1) Electrostatic Filter / Precipitators					
Electrostatic Precipitator (1012)	"Smog-Hog" PSG Electrostatic Precipitator / Model : PSG - followed by 11, 12, 13, 14, 21, 22, 23, 24, 32, 33, 34, 42, 43, 44, 52, 53, 54, 62, 63, 64; followed by - 1 / Application : Mechanical ventilating system and kitchen exhaust system / Construction : Duct-type unit of same basic design for all models with identical components, comprising a steel cabinet, aluminium collector cells, high voltage power supply, pre/post filters (aluminium) and with no air-moving fan. The difference between models is in the number and arrangement of the collector cells used. / Power Supply : Suitable for 220V, 50Hz single phase supply (With built-in step down transformer by manufacturer)	United Air Specialists, Inc. USA	20/2/2018	Subject to review with the updating of edition of the test standard	a) The electrostatic precipitator shall not be used in hazardous locations or for the handling of hazardous gases/ mixtures. b) All units being installed remain Listed Products under the Intertek Product Certificate Directory and bear the appropriate Intertek ETL Listing Mark. c) This letter supersedes our previous one of the same series dated 6 April 2016.
Electrostatic Precipitator (1063)	"Smog-Hog" PSH Electrostatic Precipitator / Model : PSH - followed by 11, 12, 13, 14, 21, 22, 23, 24, 32, 33, 34, 42, 43, 44, 52, 53, 54, 62, 63, 64; followed by - 1 / Application : Mechanical ventilating system and kitchen exhaust system / Construction : Duct-type unit of same basic design for all models with identical component comprising a steel cabinet, aluminium collector cells, high voltage power supply, pre/post filters (aluminium) and with no air-moving fan. The difference between models is in the number and arrangement of the collector cells used. / Power Supply : Suitable for 220V, 50Hz single phase supply (With built-in step down transformer by manufacturer)	CLARCOR Filtration (China) Co., Ltd.	2/11/2018	Subject to review with the updating of edition of the test standard	a) The electrostatic precipitator shall not be used in hazardous locations or for the handling of hazardous gases / mixtures. b) All units being installed remain Listed Products under the Intertek Product Certificate Directory and bear the appropriate Intertek ETL Listing Mark.

LIST OF PRODUCT APPROVED FOR USE IN VENTILATING SYSTEMS

Ventilation Systems Group of FIRE SERVICES DEPARTMENT

Note (1) : For details of the acceptance criteria / conditions , please refer to the FSD approval letter(s) issued to the manufacturer / authorized supplier(s) of the products

Note (2) : Please refer to FSD Circular Letter No. 1/2024 for guidance for application for approval of Fusible Link and Electrostatic Filter or Precipitator products. If the product has been listed and published by a Product Certification Body (PCB) and Product Certification, it is deemed to be accepted by the FSD subject to such product being in conforming with all local relevant local requirements on product specification and its application in ventilating systems. As stipulated under Chapter 123J - Building (Ventilating Systems) Regulations and Chapter 132CE - Ventilation of Scheduled Premises Regulation, fusible link and electrostatic filter or precipitator shall be of a type approved by the Director of Fire Services. In this connection, application for FSD approval on all fusible link and electrostatic filter or precipitator for use in ventilating systems is required.

TYPE	BRAND NAME / MODELS / DESCRIPTION	MANUFACTURER / AUTHORIZED SUPPLIER	FSD ACCEPTANCE DATE	DATE TO REVIEW (Subject to Renewal)	Remarks
Electrostatic Precipitator (1069)	"Airscren 2300" Electrostatic Precipitator / Model : "Airscren 2300" Electronic Air Filter / Application : Mechanical ventilation system according to manufacturer's instruction / Construction : A two inches thick panel type device comprising a conductive screen sandwiched between two layers of fiberglass filter (tested to UL 900, Class II) and housed in a metal casing incorporated with a power adaptor. / Power Supply : Input rating of 120V AC, 50 Hz, single phase / Certificate of Compliance : No. 1362961 of 12.3.2015 issued by CSA International	InnerEco Environmental Inc., Canada	14/11/2018	March 2025	a) The product shall not be used in kitchen exhaust and hazardous locations or for the handling of hazardous gases/mixtures. b) The product shall bear the appropriate CSA identification markings. c) The product shall comply with safety requirements in the manufacturer's recommendations. d) The product shall not be used in Hong Kong households in accordance with the Electrical Products (Safety) Regulation. e) The letter supersedes our previous one of the same series dated 22.12.2009
Electrostatic Precipitator (1074)	"AIR-TECH" AT, AT-H and AT-H/W Series Electrostatic Precipitators / Product Name : "AIR-TECH" Electrostatic Precipitator / Model : AT-01, AT02, AT03, AT-01H, AT-02H, AT-03H, AT-01/W, AT-02/W, AT-03/W, AT-01H/W, AT-02H/W and AT-03H/W / Description : Duct-type unit comprising powder painted steel casing, aluminium pre/after mesh filter, ionizer with tungsten wire in aluminium frame, aluminium collector cell and factory inbuilt control panel which includes power pack and electrical safety interlocking system. / Power Supply : Suitable for 220V, 50Hz single phase supply	Auto Integrated Ltd., PRC	20/11/2018	Subject to review with the updating of edition of the test standard	a) The electrostatic precipitator shall not be used in hazardous locations or for the handling of hazardous gases/ mixtures. b) All units shall be accompanied with an ex-factory inspection certificates issued by Guangzhou Quality Supervision and Testing Institute (廣州質量監督檢測研究院) to verify compliance with the above mentioned standards. c) This letter supersedes our previous one of the same series dated 13 August 2014.
Electrostatic Precipitator (1080)	"Fangda" FD Series Electrostatic Precipitators / Product Name : " Fangda" Electrostatic Precipitator / Model : FT-3000-1, 3000-2,3000-3, 3000-4 & 3000-5 / Description : Duct-type unit, comprising stainless steel casing, stainless steel pre/after mesh filter, stainless steel ionizer and collector cell , factory inbuilt control panel which includes solid-state power pack and electrical interlocking system. / Power Supply : Suitable for 220V, 50Hz single phase supply	Shenzhen Hengfeng Kitchen Utensils Equipment Co., Ltd.	14/12/2018	August 2028	a) The electrostatic precipitator shall not be used in hazardous locations or for the handling of hazardous gases/ mixtures. b) All units shall be accompanied with an ex-factory inspection certificates issued by Guangzhou Quality Supervision and Testing Institute (廣州質量監督檢測研究院) to verify compliance with the above mentioned standards. c) This assessment is subject to review by August 2028 or with the updating of the test standard.

LIST OF PRODUCT APPROVED FOR USE IN VENTILATING SYSTEMS

Ventilation Systems Group of FIRE SERVICES DEPARTMENT

Note (1) : For details of the acceptance criteria / conditions , please refer to the FSD approval letter(s) issued to the manufacturer / authorized supplier(s) of the products

Note (2) : Please refer to FSD Circular Letter No. 1/2024 for guidance for application for approval of Fusible Link and Electrostatic Filter or Precipitator products. If the product has been listed and published by a Product Certification Body (PCB) and Product Certification, it is deemed to be accepted by the FSD subject to such product being in conforming with all local relevant local requirements on product specification and its application in ventilating systems. As stipulated under Chapter 123J - Building (Ventilating Systems) Regulations and Chapter 132CE - Ventilation of Scheduled Premises Regulation, fusible link and electrostatic filter or precipitator shall be of a type approved by the Director of Fire Services. In this connection, application for FSD approval on all fusible link and electrostatic filter or precipitator for use in ventilating systems is required.

TYPE	BRAND NAME / MODELS / DESCRIPTION	MANUFACTURER / AUTHORIZED SUPPLIER	FSD ACCEPTANCE DATE	DATE TO REVIEW (Subject to Renewal)	Remarks
Electrostatic Precipitator (1092)	"Fangda" FD Series Electrostatic Precipitators / Product Name : " Fangda" Electrostatic Precipitator / Model : FD-3000-1, 3000-2,3000-3, 3000-4 & 3000-5 / Description : Duct-type unit, comprising stainless steel casing, stainless steel pre/after mesh filter, stainless steel ionizer and collector cell , factory inbuilt control panel which includes solid-state power pack and electrical interlocking system. / Power Supply : Suitable for 220V, 50Hz single phase supply	Shenzhen Hengfeng Kitchen Utensils Equipment Co., Ltd.	25/2/2019	August 2028	a) The electrostatic precipitator shall not be used in hazardous locations or for the handling of hazardous gases/ mixtures. b) All units shall be accompanied with an ex-factory inspection certificates issued by Guangzhou Quality Supervision and Testing Institute (廣州質量監督檢測研究院) to verify compliance with the above mentioned standards. c) This letter supersedes our previous letter of the same reference dated 14.12.2018. d) This assessment is subject to review by August 2028 or with the updating of the test standard.
Electrostatic Precipitator (1094)	"Man Po" MP Series Electrostatic Precipitators / Product Name : "Man Po" Electrostatic Precipitator / Model : "MP" Series a) F101,F102,F103, F104 b) F202, F203,F204 c) F303,304 / Description : Duct-type unit, comprising stainless steel or galvanized steel casing, stainless steel pre / after mesh filters, stainless steel ionizer and collector cell (stainless steel and aluminium), auto-wash system and factory inbuilt control panel which includes power pack and electrical safety interlocking system. / Power Supply : Suitable for 220V, 50Hz single phase supply	Guangzhou Man Po Kitchen Equipment Co., Ltd., PRC	1/4/2019	January 2029	a) The electrostatic precipitator shall not be used in hazardous locations or for the handling of hazardous gases / mixtures. b) All units shall be accompanied with an ex-factory inspection certificates issued by Guangzhou Quality Supervision and Testing Institute (廣州質量監督檢測研究院) to verify compliance with the above mentioned standards. c) This assessment letter supersedes our previous one of the same series dated 4.3.2014. d) This assessment is subject to review by January 2029 or with the updating of the test standard.

LIST OF PRODUCT APPROVED FOR USE IN VENTILATING SYSTEMS

Ventilation Systems Group of FIRE SERVICES DEPARTMENT

Note (1) : For details of the acceptance criteria / conditions , please refer to the FSD approval letter(s) issued to the manufacturer / authorized supplier(s) of the products

Note (2) : Please refer to FSD Circular Letter No. 1/2024 for guidance for application for approval of Fusible Link and Electrostatic Filter or Precipitator products. If the product has been listed and published by a Product Certification Body (PCB) and Product Certification, it is deemed to be accepted by the FSD subject to such product being in conforming with all local relevant local requirements on product specification and its application in ventilating systems. As stipulated under Chapter 123J - Building (Ventilating Systems) Regulations and Chapter 132CE - Ventilation of Scheduled Premises Regulation, fusible link and electrostatic filter or precipitator shall be of a type approved by the Director of Fire Services. In this connection, application for FSD approval on all fusible link and electrostatic filter or precipitator for use in ventilating systems is required.

TYPE	BRAND NAME / MODELS / DESCRIPTION	MANUFACTURER / AUTHORIZED SUPPLIER	FSD ACCEPTANCE DATE	DATE TO REVIEW (Subject to Renewal)	Remarks
Electrostatic Precipitator (1096)	"Fangda" FD Series Electrostatic Precipitators / Product Name: "Fangda" Electrostatic Precipitator / Model : FD-3000-1 . 3000-2,3000-3. 3000-4 & 3000-5 / Description : Duct-type unit, comprising stainless steel casing, stainless steel pre/after mesh filter, stainless steel ionizer and collector cell , factory inbuilt control panel which includes solid-state power pack and electrical interlocking system. / Power Supply : Suitable for 220V, 50Hz single phase supply	Shenzhen Hengfeng Kitchen Utensils Equipment Co., Ltd.	25/2/2019	August 2028	a) The electrostatic precipitator shall not be used in hazardous locations or for the handling of hazardous gases/ mixtures. b) All units shall be accompanied with an ex-factory inspection certificates issued by Guangzhou Quality Supervision and Testing Institute (廣州質量監督檢測研究院) to verify compliance with the above mentioned standards. c) This letter supersedes our previous letter of the same reference dated 14.12.2018 d) This assessment is subject to review by August 2028 or with the updating of the test standard.
Electrostatic Precipitator (1106)	"Klean" Electrostatic Precipitators - BS266 Series Products / Product Name : "Klean" Electrostatic Precipitator / Model : BS-266J-20G, 20, 12G, 12 / Description : Duct-type unit, comprising mild steel cabinet, galvanized steel pre-filter, galvanized steel collection sections, stainless steel ionization section, honeycomb filter cells , factory inbuilt control panel which includes solid-state power pack and electrical interlocking system. / Power Supply : Suitable for 220V, 50Hz single phase supply	Kleantechnics Environmental Products Co., Ltd.	29/5/2019	September 2028	a) The electrostatic precipitator shall not be used in hazardous locations or for the handling of hazardous gases/ mixtures. b) All units shall be accompanied with an ex-factory inspection certificates issued by Guangzhou Quality Supervision and Testing Institute (廣州質量監督檢測研究院) to verify compliance with the above mentioned standards. c) This assessment is subject to review by September 2028 or with the updating of the test standard.

LIST OF PRODUCT APPROVED FOR USE IN VENTILATING SYSTEMS

Ventilation Systems Group of FIRE SERVICES DEPARTMENT

Note (1) : For details of the acceptance criteria / conditions , please refer to the FSD approval letter(s) issued to the manufacturer / authorized supplier(s) of the products

Note (2) : Please refer to FSD Circular Letter No. 1/2024 for guidance for application for approval of Fusible Link and Electrostatic Filter or Precipitator products. If the product has been listed and published by a Product Certification Body (PCB) and Product Certification, it is deemed to be accepted by the FSD subject to such product being in conforming with all local relevant local requirements on product specification and its application in ventilating systems. As stipulated under Chapter 123J - Building (Ventilating Systems) Regulations and Chapter 132CE - Ventilation of Scheduled Premises Regulation, fusible link and electrostatic filter or precipitator shall be of a type approved by the Director of Fire Services. In this connection, application for FSD approval on all fusible link and electrostatic filter or precipitator for use in ventilating systems is required.

TYPE	BRAND NAME / MODELS / DESCRIPTION	MANUFACTURER / AUTHORIZED SUPPLIER	FSD ACCEPTANCE DATE	DATE TO REVIEW (Subject to Renewal)	Remarks
Electrostatic Precipitator (1107)	"Klean" Electrostatic Precipitators - BS216J Series Products / Product Name : "Klean" Electrostatic Precipitator / Model : BS-261J-4K, 6K, 8K, 1 12K, 16K, 20K, 25K, 30K, 36K, 42K / Description : Duct-type unit, comprising mild steel cabinet, galvanized steel pre-filter, galvanized steel collection sections, stainless steel ionization section, honeycomb filter cells , factory inbuilt control panel which includes solid-state power pack and electrical interlocking system. / Power Supply : Suitable for 220V, 50Hz single phase supply	Kleantechnics Environmental Products Co., Ltd.	29/5/2019	September 2028	a) The electrostatic precipitator shall not be used in hazardous locations or for the handling of hazardous gases/ mixtures. b) All units shall be accompanied with an ex-factory inspection certificates issued by Guangzhou Quality Supervision and Testing Institute (廣州質量監督檢測研究院) to verify compliance with the above mentioned standards. c) This assessment is subject to review by September 2028 or with the updating of the edition of the test standard.
Electrostatic Precipitator (1121)	"Klean" Electrostatic Precipitator - BS266 Series Products / Product Name : "Klean" Electrostatic Precipitator / Model : BS-266J-20G, 20, 12G, 12 / Description : Duct type unit, comprising mild steel cabinet, galvanized steel pre-filter, galvanized steel collection sections, stainless steel ionization section, honeycomb filter cells , factory inbuilt control panel which includes solid-state power pack and electrical interlocking system. / Power Supply : Suitable for 220V, 50Hz single phase supply	Kleantechnics Environmental Products Co., Ltd.	8/7/2019	September 2028	a) The electrostatic precipitator shall not be used in hazardous locations or for the handling of hazardous gases/ mixtures. b) All units shall be accompanied with an ex-factory inspection certificates issued by Guangzhou Quality Supervision and Testing Institute (廣州質量監督檢測研究院) to verify compliance with the above mentioned standards. c) This assessment is subject to review by September 2028 or with the updating of the test standard.

LIST OF PRODUCT APPROVED FOR USE IN VENTILATING SYSTEMS

Ventilation Systems Group of FIRE SERVICES DEPARTMENT

Note (1) : For details of the acceptance criteria / conditions , please refer to the FSD approval letter(s) issued to the manufacturer / authorized supplier(s) of the products

Note (2) : Please refer to FSD Circular Letter No. 1/2024 for guidance for application for approval of Fusible Link and Electrostatic Filter or Precipitator products. If the product has been listed and published by a Product Certification Body (PCB) and Product Certification, it is deemed to be accepted by the FSD subject to such product being in conforming with all local relevant local requirements on product specification and its application in ventilating systems. As stipulated under Chapter 123J - Building (Ventilating Systems) Regulations and Chapter 132CE - Ventilation of Scheduled Premises Regulation, fusible link and electrostatic filter or precipitator shall be of a type approved by the Director of Fire Services. In this connection, application for FSD approval on all fusible link and electrostatic filter or precipitator for use in ventilating systems is required.

TYPE	BRAND NAME / MODELS / DESCRIPTION	MANUFACTURER / AUTHORIZED SUPPLIER	FSD ACCEPTANCE DATE	DATE TO REVIEW (Subject to Renewal)	Remarks
Electrostatic Precipitator (1122)	"Klean" Electrostatic Precipitators - BS216J Series Products / Product Name : "Klean" Electrostatic Precipitator / Model : BS-216J-4K, 6K, 8K, 1 12K, 16K, 20K, 25K, 30K, 36K, 42K / Description : Duct-type unit, comprising mild steel cabinet, galvanized steel pre-filter, galvanized steel collection sections, stainless steel ionization section, honeycomb filter cells , factory inbuilt control panel which includes solid-state power pack and electrical interlocking system. / Power Supply : Suitable for 220V, 50Hz single phase supply	Kleantechnics Environmental Products Co., Ltd.	15/7/2019	September 2028	a) The electrostatic precipitator shall not be used in hazardous locations or for the handling of hazardous gases/ mixtures. b) All units shall be accompanied with an ex-factory inspection certificates issued by Guangzhou Quality Supervision and Testing Institute (廣州質量監督檢測研究院) to verify compliance with the above mentioned standards. c) This assessment is subject to review by September 2028 or with the updating of the edition of the test standard.
Electrostatic Precipitator (1136)	"Euro Asia Technology Company Limited " Electrostatic Precipitators_ / Model : TW-KH-EAN200-UL, TW-KH-EAN400-UL, TW-KH-EAN600-UL / Application : Mechanical ventilating system / Construction : Duct-type unit of same basic design for all models with identical components, comprising a steel cabinet, aluminium collector cells, high voltage power supply, pre/post filters (aluminium) and with no air-moving fan. / Power Supply : Suitable for 220V, 50Hz single phase supply	Elastrostatic Air Cleaners, Fixed	9/9/2019	September 2028	a) The electrostatic precipitator shall not be used in hazardous locations or for the handling of hazardous gases/ mixtures. b) All units being installed remain Listed Products under the UL Certificate Directory. c) The product shall bear the appropriate UL Mark. d) This assessment is subject to review by September 2028 or with the updating of the edition of the test standard..

LIST OF PRODUCT APPROVED FOR USE IN VENTILATING SYSTEMS

Ventilation Systems Group of FIRE SERVICES DEPARTMENT

Note (1) : For details of the acceptance criteria / conditions , please refer to the FSD approval letter(s) issued to the manufacturer / authorized supplier(s) of the products

Note (2) : Please refer to FSD Circular Letter No. 1/2024 for guidance for application for approval of Fusible Link and Electrostatic Filter or Precipitator products. If the product has been listed and published by a Product Certification Body (PCB) and Product Certification, it is deemed to be accepted by the FSD subject to such product being in conforming with all local relevant local requirements on product specification and its application in ventilating systems. As stipulated under Chapter 123J - Building (Ventilating Systems) Regulations and Chapter 132CE - Ventilation of Scheduled Premises Regulation, fusible link and electrostatic filter or precipitator shall be of a type approved by the Director of Fire Services. In this connection, application for FSD approval on all fusible link and electrostatic filter or precipitator for use in ventilating systems is required.

TYPE	BRAND NAME / MODELS / DESCRIPTION	MANUFACTURER / AUTHORIZED SUPPLIER	FSD ACCEPTANCE DATE	DATE TO REVIEW (Subject to Renewal)	Remarks
Electrostatic Precipitator (1178)	"Meikong Electrostatic Air Precipitators / Product Name : "Man Po" Electrostatic Precipitator / Model : "Meikong Series MK-OF04-2-3, MK-OF06-2-3, MK-OF08-3-3, MK-OF10-3-3, MK-OF12-3-3, MK-OF14-3-3, MK-OF16-3-3, MK-OF18-3-3, MK-OF20-3-3, MK-OF25-3-3, MK-OF30-3-3, MK-OF04-2-4, MK-OF06-2-4, MK-OF04-2-4, MK-OF08-4-4, MK-OF10-4-4, MK-OF12-4-4, MK-OF14-4-4, MK-OF16-4-4, MK-OF18-4-4, MK-OF20-4-4, MK-OF25-4-4, MK-OF30-4-4, MK-OF04-3-5, MK-OF06-3-5, MK-OF08-5-5, MK-OF10-5-5, MK-OF12-5-5, MK-OF14-5-5, MK-OF16-5-5, MK-OF18-5-5, MK-OF20-5-5, MK-OF25-5-5, MK-OF30-5-5 / Description : Duct-type unit, comprising stainless steel or galvanized steel casing, stainless steel pre mesh filters, stainless steel ionizer and collector cell, which includes electrical safety interlocking system. / Power Supply : Suitable for 380V, 50Hz three phase supply	GuangDong MeiKong Electronic Technology Co., Ltd., PRC	21/5/2020	June 2029	a) The electrostatic precipitator shall not be used in hazardous locations or for the handling of hazardous gases/ mixtures. b) All units shall be accompanied with an ex-factory inspection certificates issued by Guangdong Testing Institute of Product Quality Supervision to verify compliance with the above mentioned standards.

LIST OF PRODUCT APPROVED FOR USE IN VENTILATING SYSTEMS

Ventilation Systems Group of FIRE SERVICES DEPARTMENT

Note (1) : For details of the acceptance criteria / conditions , please refer to the FSD approval letter(s) issued to the manufacturer / authorized supplier(s) of the products

Note (2) : Please refer to FSD Circular Letter No. 1/2024 for guidance for application for approval of Fusible Link and Electrostatic Filter or Precipitator products. If the product has been listed and published by a Product Certification Body (PCB) and Product Certification, it is deemed to be accepted by the FSD subject to such product being in conforming with all local relevant local requirements on product specification and its application in ventilating systems. As stipulated under Chapter 123J - Building (Ventilating Systems) Regulations and Chapter 132CE - Ventilation of Scheduled Premises Regulation, fusible link and electrostatic filter or precipitator shall be of a type approved by the Director of Fire Services. In this connection, application for FSD approval on all fusible link and electrostatic filter or precipitator for use in ventilating systems is required.

TYPE	BRAND NAME / MODELS / DESCRIPTION	MANUFACTURER / AUTHORIZED SUPPLIER	FSD ACCEPTANCE DATE	DATE TO REVIEW (Subject to Renewal)	Remarks
Electrostatic Precipitator (1223)	"Clean Air" Electrostatic Precipitator GAE Series / Model : GAE - followed by -250, -375, -500, -625, -750, -875; may be followed by /w; maybe followed by -1, -2, -3,-4 (The digital in model (-1, -2, -3,-4) indicates the number of tiers high, "w" indicates to incorporate automatic cleaning function sump pump) / Application : Mechanical ventilating system and kitchen exhaust system / Construction : Duct-type unit of same basic design for all models with identical components, comprising a galvanized steel cabinet, aluminium collector cells, high voltage power supply, pre/post filters (aluminium) and with no air-moving fan. The different between models is in the number and arrangement of the collector cells used. / Power Supply : Suitable for 220V, 50Hz single phase supply (With built-in step down transformer by manufacturer)	Shandong environmental pollution control system, Co. Ltd.	8/9/2020	May 2025	a) The electrostatic precipitator shall not be used in hazardous locations or for the handling of hazardous gases/ mixtures. b) All units being installed remain Listed Products under the Intertek Product Certificate Directory and bear the appropriate Intertek ETL Listing Mark.
Electrostatic Precipitator (1229)	"Filtornado" FTD Series Electrostatic Precipitators / Product Name : "Filtornado" Electrostatic Precipitator / Model : FT-01, FT02, FT03 / Description : Duct-type unit, comprising stainless steel casing, stainless steel filter, stainless steel ionizer, stainless steel collection cell and factory inbuilt control panel which includes electrical safety interlocking system. / Power Supply : Suitable for 220V, 50Hz single phase supply	Shenzhen Hengfeng Kitchen Utensils Equipment Co., Ltd. PRC	23/9/2020	April 2025	a) The electrostatic precipitator shall not be used in hazardous locations or for the handling of hazardous gases/ mixtures. b) All units shall be accompanied with an ex-factory inspection certificates issued by Guangzhou Quality Supervision and Testing Institute (廣州質量監督檢測研究院) to verify compliance with the above mentioned standards.

LIST OF PRODUCT APPROVED FOR USE IN VENTILATING SYSTEMS

Ventilation Systems Group of FIRE SERVICES DEPARTMENT

Note (1) : For details of the acceptance criteria / conditions , please refer to the FSD approval letter(s) issued to the manufacturer / authorized supplier(s) of the products

Note (2) : Please refer to FSD Circular Letter No. 1/2024 for guidance for application for approval of Fusible Link and Electrostatic Filter or Precipitator products. If the product has been listed and published by a Product Certification Body (PCB) and Product Certification, it is deemed to be accepted by the FSD subject to such product being in conforming with all local relevant local requirements on product specification and its application in ventilating systems. As stipulated under Chapter 123J - Building (Ventilating Systems) Regulations and Chapter 132CE - Ventilation of Scheduled Premises Regulation, fusible link and electrostatic filter or precipitator shall be of a type approved by the Director of Fire Services. In this connection, application for FSD approval on all fusible link and electrostatic filter or precipitator for use in ventilating systems is required.

TYPE	BRAND NAME / MODELS / DESCRIPTION	MANUFACTURER / AUTHORIZED SUPPLIER	FSD ACCEPTANCE DATE	DATE TO REVIEW (Subject to Renewal)	Remarks
Electrostatic Precipitator (1244)	"Filtornado" FTD Series Electrostatic Precipitators / Product Name : "Filtornado" Electrostatic Precipitator / Model : FTD-01, FTD-02, FTD-03 / Description : Duct-type unit, comprising stainless steel casing, stainless steel filter, stainless steel ionizer, stainless steel collection cell and factory inbuilt control panel which includes electrical safety interlocking system. / Power Supply : Suitable for 220V, 50Hz single phase supply	Shenzhen Hengfeng Kitchen Utensils Equipment Co., Ltd PRC	6/11/2020	April 2025	a) The electrostatic precipitator shall not be used in hazardous locations or for the handling of hazardous gases/ mixtures. b) All units shall be accompanied with an ex-factory inspection certificates issued by Guangzhou Quality Supervision and Testing Institute (廣州質量監督檢測研究院) to verify compliance with the above mentioned standards. c) This assessment letter supersedes our previous one of the same series dated 23.9.2020
Electrostatic Precipitator (1347)	"Air-Quality" Electrostatic Air Precipitators / Brand Name : Air Quality / Model : AutoClean Series F61: F61A (AutoClean 2000) F61B (AutoClean 4000) F61C (AutoClean 8000) Smokemaster Series F72: F72A (Excel Air 2000) F72B (Excel Air 4000) F72C / Descriptions : Duct-type unit of similar design for both series, comprising a steel cabinet, single or multiple electrostatic cell units, high voltage power supply and aluminum pre/post filters, and without air-moving fans / Operating Voltage : Suitable for 220V, 50 Hz single phase supply	Air-Quality Engineering, Inc., USA	9/2/2022	February 2027	a) The electrostatic air cleaners shall not be used in hazardous locations or for the handling of hazardous gases/ mixtures b) All units shall bear the appropriate 'ETL' markings c) The following shall be clearly marked: - Manufacturer's name -Country of origin - Type and model number d) This assessment letter supersedes our previous one of the same series dated 01.02.2017 e) This letter is subject to review by February 2027.

LIST OF PRODUCT APPROVED FOR USE IN VENTILATING SYSTEMS

Ventilation Systems Group of FIRE SERVICES DEPARTMENT

Note (1) : For details of the acceptance criteria / conditions , please refer to the FSD approval letter(s) issued to the manufacturer / authorized supplier(s) of the products

Note (2) : Please refer to FSD Circular Letter No. 1/2024 for guidance for application for approval of Fusible Link and Electrostatic Filter or Precipitator products. If the product has been listed and published by a Product Certification Body (PCB) and Product Certification, it is deemed to be accepted by the FSD subject to such product being in conforming with all local relevant local requirements on product specification and its application in ventilating systems. As stipulated under Chapter 123J - Building (Ventilating Systems) Regulations and Chapter 132CE - Ventilation of Scheduled Premises Regulation, fusible link and electrostatic filter or precipitator shall be of a type approved by the Director of Fire Services. In this connection, application for FSD approval on all fusible link and electrostatic filter or precipitator for use in ventilating systems is required.

TYPE	BRAND NAME / MODELS / DESCRIPTION	MANUFACTURER / AUTHORIZED SUPPLIER	FSD ACCEPTANCE DATE	DATE TO REVIEW (Subject to Renewal)	Remarks
Electrostatic Precipitator (1387)	"AIR-TECH" AT, AT/W, AT-H and AT-H/W Series Electrostatic Precipitators / Product Name : "AIR-TECH" Electrostatic Precipitator / Model AT-01, AT-02, AT-03, AT-04, AT-01H, AT-02H, AT-03H, AT-01/W, AT-02/W, AT-03/W, AT-04/W, AT-01H/W, AT-02H/W and AT-03H/W / Description : Duct-type unit, comprising powder paint steel casing, aluminium pre/after mesh filter, ionizer with tungsten wire in aluminium frame, aluminium collector cell and factory inbuilt control panel including power pack and electrical safety interlocking system. / Power Supply : Suitbale for 220V, 50Hz single phase supply / Testing Laboratory : Guangzhou Quality Supervision and Testing Institute (廣州質量監督檢測研究院) / Test Standards : a. UL 710 (6 th Edition) -- Exhaust Hoods for Commercial Cooking Equipment b. UL 867 (5 th Edition) -- Standard for Safety-Electrostatic Air Cleaners / Test Results : Confirm to the applicable test criteria	Auto Integrated Limited	8/8/2022	July 2027	a) The electrostatic precipitator shall not be used in hazardous locations or for the handling of hazardous gases / mixtures. b) All units shall be accompanied with an ex-factory inspection certificates issued by Guangzhou Quality Supervision and Testing Institute to verify compliance with the above-mentioned standards. c) This letter supersedes our previous one of the same series dated 20 Nov 2018. d) This assessment is subject to review by July 2027.
Electrostatic Precipitator (1432)	"EFB" Electrostatic Precipitators (Air Cleaners) / Model : EFB 1H2B, EFB 1H2BG, EFB 1H2BX, EFB2H2B, EFB2H2BG, EFB2H2BX, EFB3H2B, EFB3H2BG, EFB3H2BX / Operating Voltage : 220V/50Hz single-phase supply.	Johnson Controls Air Conditioning and Refrigeration (WUXI) Co. Ltd.	28/4/2023	April 2028	a) The electrostatic air cleaner shall not be used in hazardous locations or for handling hazardous gases/mixtures. b) The electrostatic air cleaner shall bear the "UL Listing Mark". c) The following shall be clearly marked : - Manufacturer' s name - Country of origin - Type and Model number d) This assessment is subject to review by April 2028.

LIST OF PRODUCT APPROVED FOR USE IN VENTILATING SYSTEMS

Ventilation Systems Group of FIRE SERVICES DEPARTMENT

Note (1) : For details of the acceptance criteria / conditions , please refer to the FSD approval letter(s) issued to the manufacturer / authorized supplier(s) of the products

Note (2) : Please refer to FSD Circular Letter No. 1/2024 for guidance for application for approval of Fusible Link and Electrostatic Filter or Precipitator products. If the product has been listed and published by a Product Certification Body (PCB) and Product Certification, it is deemed to be accepted by the FSD subject to such product being in conforming with all local relevant local requirements on product specification and its application in ventilating systems. As stipulated under Chapter 123J - Building (Ventilating Systems) Regulations and Chapter 132CE - Ventilation of Scheduled Premises Regulation, fusible link and electrostatic filter or precipitator shall be of a type approved by the Director of Fire Services. In this connection, application for FSD approval on all fusible link and electrostatic filter or precipitator for use in ventilating systems is required.

TYPE	BRAND NAME / MODELS / DESCRIPTION	MANUFACTURER / AUTHORIZED SUPPLIER	FSD ACCEPTANCE DATE	DATE TO REVIEW (Subject to Renewal)	Remarks
Electrostatic Precipitator (1489)	"CLEAN AIR" Electrostatic Precipitator GAE Series / Model : GAE - followed by -250, -375, -500, -625, -750, -875; may be followed by /w; maybe followed by -1,-2,-3,-4 (The digital in model (-1,-2,-3,-4) indicates the number of tiers high, " w" indicates to incorporate automatic cleaning function sump pump)/ Application : Mechanical ventilating system and kitchen exhaust system / Construction : Duct-type unit of same basic design for all models with identical components, comprising a galvanized steel cabinet, aluminium collector cells, high voltage power supply, pre/post filters (aluminium) and with no air- moving fan. The difference between models is in the number and arrangement of the collector cells used. / Power Supply : Suitable for 220V, 50Hz single phase supply (With built-in step down transformer by manufacturer).	Shandong environmental pollution control system, Co. Ltd. / PRC	19/4/2024	April 2029	a) The electrostatic precipitator shall not be used in hazardous locations or for the handling of hazardous gases/ mixtures. b) All units being installed remain Listed Products under the Intertek Product Certificate Directory and bear the appropriate Intertek ETL Listing Mark. c) This assessment is subject to review by April 2029.
靜電聚塵器 (1528)	"環球廚具" GL-JD-6A 靜電聚塵器 / 過濾器型號 : GL-JD-6A / 應用 : 機動式通風系統及廚房排氣系統 / 建造結構 : 利用靜電式原理, 通過電離、荷電、收集等程式進行淨化油煙油霧廢氣中的污染粒子, 淨化效率高。高頻電源控制系統穩定油煙淨化設備的淨化效率 / 電源 : 適用於220V、50Hz 單相電源	深圳市廣藍環保科技有限公司	2024 年 11 月 12 日	2029 年 11 月	備註 : i) 靜電除塵器不得用於危險區域或用於處理危險氣體 / 混合物 (ii) 這評估將在 2029 年 11 月之前再接受審查

LIST OF PRODUCT APPROVED FOR USE IN VENTILATING SYSTEMS

Ventilation Systems Group of FIRE SERVICES DEPARTMENT

Note (1) : For details of the acceptance criteria / conditions , please refer to the FSD approval letter(s) issued to the manufacturer / authorized supplier(s) of the products

Note (2) : Please refer to FSD Circular Letter No. 1/2024 for guidance for application for approval of Fusible Link and Electrostatic Filter or Precipitator products. If the product has been listed and published by a Product Certification Body (PCB) and Product Certification, it is deemed to be accepted by the FSD subject to such product being in conforming with all local relevant local requirements on product specification and its application in ventilating systems. As stipulated under Chapter 123J - Building (Ventilating Systems) Regulations and Chapter 132CE - Ventilation of Scheduled Premises Regulation, fusible link and electrostatic filter or precipitator shall be of a type approved by the Director of Fire Services. In this connection, application for FSD approval on all fusible link and electrostatic filter or precipitator for use in ventilating systems is required.

TYPE	BRAND NAME / MODELS / DESCRIPTION	MANUFACTURER / AUTHORIZED SUPPLIER	FSD ACCEPTANCE DATE	DATE TO REVIEW (Subject to Renewal)	Remarks
靜電聚塵器 (1529)	有關 "環球廚具" GL-JD-10A 靜電聚塵器 / 過濾器型號 : GL-JD-10A / 應用 : 機動式通風系統及廚房排氣系統 / 建造結構 : 利用靜電式原理, 通過電離、荷電、收集等程式進行淨化油煙油霧廢氣中的污染粒子, 淨化效率高。高頻電源控制系統穩定油煙淨化設備的淨化效率 / 電源 : 適用於220V、50Hz 單相電源	深圳市廣藍環保科技有限公司	2024 年11月12日	2029 年11月	備註 : i) 靜電除塵器不得用於危險區域或用於處理危險氣體/ 混合物 (ii) 這評估將在2029 年 11 月之前再接受審查
(2) Fusible Links					
Fusible Link (1027)	"Globe" Model G Fusible Link / Model/Type : Model G 155°F (68°C) / Temperature Rating : Not exceeding 69°C	GLOBE Technologies Corp., USA	31/5/2018	April 2023	a) The fusible link shall bear the following identification marks on its body: i) Brand name ii) Temperature rating mark of 155°F & iii) UL mark b) For loads from 3 to 45 lbs. inclusive c) Our previous letter of the same series dated 20.1.2016 and 29.5.2018 are hereby superseded.
Electro Thermal Link(1066)	"EVERTOP" SR Model ETL II Electro Thermal Link / Model/Type : EVERTOP SR Model ETL II / Temperature Rating : Not exceeding 69°C	GLOBE Technologies Corp., USA	6/11/2018	October 2023	a) For loads from 5 to 40 lbs. inclusive b) This letter supersedes our previous one of the same series dated 4.7.2014.
Fusible Link (1072)	"TROX" 0571 68°C and 0572 68°C Fusible Links / Type/Model : Fusible Links a) "TROX 0571 68°C" Fusible Link b) "TroX 0572 68°C" Fusible Link / Temperature Rating : Not exceeding 69°C	TROX Malaysia Sdn. Bhd.	19/11/2018	October 2023	a) The product shall bear the following identification marks on their bodies: i) Brand and model names ii) Temperature rating

LIST OF PRODUCT APPROVED FOR USE IN VENTILATING SYSTEMS

Ventilation Systems Group of FIRE SERVICES DEPARTMENT

Note (1) : For details of the acceptance criteria / conditions , please refer to the FSD approval letter(s) issued to the manufacturer / authorized supplier(s) of the products

Note (2) : Please refer to FSD Circular Letter No. 1/2024 for guidance for application for approval of Fusible Link and Electrostatic Filter or Precipitator products. If the product has been listed and published by a Product Certification Body (PCB) and Product Certification, it is deemed to be accepted by the FSD subject to such product being in conforming with all local relevant local requirements on product specification and its application in ventilating systems. As stipulated under Chapter 123J - Building (Ventilating Systems) Regulations and Chapter 132CE - Ventilation of Scheduled Premises Regulation, fusible link and electrostatic filter or precipitator shall be of a type approved by the Director of Fire Services. In this connection, application for FSD approval on all fusible link and electrostatic filter or precipitator for use in ventilating systems is required.

TYPE	BRAND NAME / MODELS / DESCRIPTION	MANUFACTURER / AUTHORIZED SUPPLIER	FSD ACCEPTANCE DATE	DATE TO REVIEW (Subject to Renewal)	Remarks
Fusible Link (1097)	"Ruskin" EFL155 Electric Fuse Link / Model/Type : EFL155: bimetallic re-settable heat sensing device / Temperature Rating : 155°F (68.3°C)	Ruskin Co., USA	14/4/2019	August 2024	a) The device shall bear the following identification marks on its body: i) Brand and model names ii) Temperature rating b) Valid sample test report prepared by the manufacturer shall be made available for inspection upon request. c) This letter supersedes our previous one of the same series dated 3.11.2014 d) This assessment is subject to review in August 2024. In view of the validity of test certificates by a recognized laboratory is only 10 years from its issuance according to FSD Circular Letter No. 1/2007, a new valid test certificate is required to support the next application in 2024.
Fusible Link (1175)	"K.W." 68.33°C Fusible Link / Type/Model : Fusible Link a) KWL b) KWs / Temperature Rating : 68.33°C	K-Win Metal Works Manufactory Company	21/5/2020	February 2029	a) For both sizes, they shall bear the following identification marks on their bodies: i) Brand and model names ii) Temperature rating iii) Batch identification (With an alphabet and a 2 -digit figure standing for the batch number and the year of production respectively). b) This letter supersedes our previous one of the same series dated 20 June 2015.
Fusible Link (1189)	"Globe" model JS Fusible Link / Model/Type : JS / Temperature Rating : Not exceeding 69°C / Product Certification : The product is "UL" listed under File JGIX.R1431	GLOBE Technologies Corporation, USA	4/6/2020	Subject to review with the updating of edition of the test standard	a) The fusible link shall bear the following identification marks on its body: i) Brand name ii) Temperature rating iii) UL mark
Fusible Link (1190)	"PHL" (USA) Reusable Electro-Thermal Link / Model/Type : E-5720, Resettable electro-thermal link / Temperature Rating : Not exceeding 69°C / Product Certification : The product is "UL" listed under File JGIX.R1431.	GLOBE Technologies Corporation, USA	4/6/2020	Subject to review with the updating of edition of the test standard	a) The device shall bear the following identification marks on its body: i) Brand and model names ii) Temperature rating iii) UL mark b) This assessment letter supersedes our previous one of the same series dated 4.8.2015

LIST OF PRODUCT APPROVED FOR USE IN VENTILATING SYSTEMS

Ventilation Systems Group of FIRE SERVICES DEPARTMENT

Note (1) : For details of the acceptance criteria / conditions , please refer to the FSD approval letter(s) issued to the manufacturer / authorized supplier(s) of the products

Note (2) : Please refer to FSD Circular Letter No. 1/2024 for guidance for application for approval of Fusible Link and Electrostatic Filter or Precipitator products. If the product has been listed and published by a Product Certification Body (PCB) and Product Certification, it is deemed to be accepted by the FSD subject to such product being in conforming with all local relevant local requirements on product specification and its application in ventilating systems. As stipulated under Chapter 123J - Building (Ventilating Systems) Regulations and Chapter 132CE - Ventilation of Scheduled Premises Regulation, fusible link and electrostatic filter or precipitator shall be of a type approved by the Director of Fire Services. In this connection, application for FSD approval on all fusible link and electrostatic filter or precipitator for use in ventilating systems is required.

TYPE	BRAND NAME / MODELS / DESCRIPTION	MANUFACTURER / AUTHORIZED SUPPLIER	FSD ACCEPTANCE DATE	DATE TO REVIEW (Subject to Renewal)	Remarks
Fusible Link (1202)	"ACL [®] " 68.33 °C Fusible Link Standard Length (58mm) and Short Length (28mm) / Type/Model : Fusible Link / "ACL [®] " 68.33 °C a) Standard Length (58mm) b) short length (28mm) / Temperature Rating : 68.33°C	Dongguan Juwun Rubber & Plastic Products Co., Ltd.	15/7/2020	January 2025	a) For both sizes, they shall bear the following identification marks on their bodies: i) "ACL [®] " Trade mark ii) Temperature grade of 68.33°C iii) Date Code, Lot & Serial reference on one side b) For static loading up to 3 kg. c) This letter <u>supersedes</u> our previous letter of the same series dated 21 May 2020.
Fusible Link (1208)	"PHL" model E-5720 Resettable Electro-Thermal Link Model /Type : E-5720, Resettable electro-thermal Link / Temperature Rating : Not exceeding 69°C / Product Certification : The product is "UL" listed under File JGIX.R1431. The fusible link shall maintain its status as "UL" listed product	GLOBE Technologies Corporation, USA	30/7/2020	July 2025	a) The device shall bear the following identification marks on its body: i) Brand and model names ii) Temperature rating iii) UL mark b) The fusible link shall maintain its status as a "UL" listed product.
Fusible Link (1211)	"Ruskin" Fusible Link / Model/Type : Model A Extended Length / Temperature Rating 68°C (155°F) / Product Certification : The product is "UL" listed under File JGIX.R1431. The fusible link shall maintain it status as "UL" listed product	Ruskin Company, USA	4/8/2020	July 2025	a) For loads from 2 to 40 lbs inclusive. b) The product shall carry the appropriate UL and temperature rating marks. c) This assessment supersedes our previous one of the same series dated 2.12.2015
Fusible Link (1212)	"PHL" (USA) Reusable Electro-Thermal Link / Model/Type : E-5720, Resettable electro-thermal link/ Temperature Rating : Not exceeding 69°C / Product Certification : The product is "UL" listed under File JGIX. R1431. The fusible link shall maintain its status as "UL" listed product	GLOBE Technologies Corporation, USA	7/8/2020	Subject to review with the updating of edition of the test standard	a) The device shall bear the following identification marks on its body: i) Brand and model names ii) Temperature rating iii) UL mark b) The fusible link shall maintain its status as a "UL" listed product. c) This assessment letter supersedes our previous one of the same series dated 22.5.2020 for <u>amendment</u> on the company name.

LIST OF PRODUCT APPROVED FOR USE IN VENTILATING SYSTEMS

Ventilation Systems Group of FIRE SERVICES DEPARTMENT

Note (1) : For details of the acceptance criteria / conditions , please refer to the FSD approval letter(s) issued to the manufacturer / authorized supplier(s) of the products

Note (2) : Please refer to FSD Circular Letter No. 1/2024 for guidance for application for approval of Fusible Link and Electrostatic Filter or Precipitator products. If the product has been listed and published by a Product Certification Body (PCB) and Product Certification, it is deemed to be accepted by the FSD subject to such product being in conforming with all local relevant local requirements on product specification and its application in ventilating systems. As stipulated under Chapter 123J - Building (Ventilating Systems) Regulations and Chapter 132CE - Ventilation of Scheduled Premises Regulation, fusible link and electrostatic filter or precipitator shall be of a type approved by the Director of Fire Services. In this connection, application for FSD approval on all fusible link and electrostatic filter or precipitator for use in ventilating systems is required.

TYPE	BRAND NAME / MODELS / DESCRIPTION	MANUFACTURER / AUTHORIZED SUPPLIER	FSD ACCEPTANCE DATE	DATE TO REVIEW (Subject to Renewal)	Remarks
Fusible Link (1219)	"Globe" model "JS" Fusible Link for LASER 9020 & 9021 series Curtain Type Fire Dampers / Model/Type : JS / Temperature Rating : Not exceeding 69°C / Product Certification : The product is "UL" listed under File JGIX.R1431. The fusible link shall maintain its status as "UL" listed product	GLOBE Technologies Corporation, USA	4/9/2020	August 2025	a) The fusible link shall bear the following identification marks on its body: i) Brand name ii) Temperature rating & iii) UL mark b) The fusible link shall maintain its status as a "UL" listed product.
Fusible Link (1258)	"S&R Products Model ETL II (Delta)" Electro Thermal Link / Model/Type : "S&R Products Model ETL II (Delta)" / Temperature Rating : 69°C (156°F)	GLOBE Technologies Corporation, USA	24/12/2020	December 2025	a) For loads from 5 to 40 lbs. inclusive b) The product shall bear the following identification marks on the body: i) Brand and model names ii) Temperature rating iii) UL listed symbol mark. c) This assessment letter supersedes our previous one of the same series dated 7.6.2016.
Fusible Link (1265)	"Ruskin" 155°F Fusible Link / Model : Model A Extended Length / Temperature Rating : 155°F / Product Certification : The product is "UL" listed under File JGIX.R8833. The fusible link shall maintain its status as "UL" listed product	Ruskin Company, USA	21/1/2021	January 2026	a) The fusible link shall bear the following identification marks on its body: i) Brand name ii) Temperature rating & iii) UL mark b) The fusible link shall maintain its status as a "UL" listed product.
Fusible Link (1271)	"Ruskin" 155°F Fusible Link / Model : Model A / Temperature Rating : 155°F / Product Certification : The product is "UL" listed under File JGIX.R8833. The fusible link shall maintain its status as "UL" listed product	Ruskin Company, USA	24/2/2021	January 2026	a) The fusible link shall bear the following identification marks on its body: i) Brand name ii) Temperature rating & iii) UL mark b) The fusible link shall maintain its status as a "UL" listed product. c) This assessment is subject to review by January 2026.

LIST OF PRODUCT APPROVED FOR USE IN VENTILATING SYSTEMS

Ventilation Systems Group of FIRE SERVICES DEPARTMENT

Note (1) : For details of the acceptance criteria / conditions , please refer to the FSD approval letter(s) issued to the manufacturer / authorized supplier(s) of the products

Note (2) : Please refer to FSD Circular Letter No. 1/2024 for guidance for application for approval of Fusible Link and Electrostatic Filter or Precipitator products. If the product has been listed and published by a Product Certification Body (PCB) and Product Certification, it is deemed to be accepted by the FSD subject to such product being in conforming with all local relevant local requirements on product specification and its application in ventilating systems. As stipulated under Chapter 123J - Building (Ventilating Systems) Regulations and Chapter 132CE - Ventilation of Scheduled Premises Regulation, fusible link and electrostatic filter or precipitator shall be of a type approved by the Director of Fire Services. In this connection, application for FSD approval on all fusible link and electrostatic filter or precipitator for use in ventilating systems is required.

TYPE	BRAND NAME / MODELS / DESCRIPTION	MANUFACTURER / AUTHORIZED SUPPLIER	FSD ACCEPTANCE DATE	DATE TO REVIEW (Subject to Renewal)	Remarks
Fusible Link (1274)	"Globe" Fusible Link / Manufacturer : Globe Technologies Corporation / Model/Type : Model GS / Temperature Rating : 68°C (155°F) / Product Certification : The product is "UL" listed under Certificate Number 20130624-R1431. The fusible link shall maintain its status as "UL" listed product	Globe Technologies Corporation	9/4/2021	June 2023	a) For loads from 3 to 45 lbs inclusive. b) The product shall carry the appropriate UL and temperature rating marks. c) The contents of this letter are subject to review in June 2023.
Fusible Link (1284)	"Ruskin" Fusible Link / Model/Type : Model A / Temperature Rating : 68°C (155°F) / Product Certification : The product is "UL" listed under File R8833. The fusible link shall maintain its status as "UL" listed product	Ruskin Company, USA	18/5/2021	July 2025	a) For loads from 2 to 40 lbs inclusive. b) The product shall carry the appropriate UL and temperature rating marks. c) This assessment supersedes our previous one of the same series dated 4.8.2020 d) The contents of this letter are subject to review in July 2025.
Resettable Electric Fuse Link (1291)	"Ruskin" EFL 155 Electric Fuse Link / Model/Type : EFL155: Electric Resettable Fuse Link / Temperature Rating : 155°F (68°C)	Ruskin (Thailand) Co., Ltd.	4/6/2021	May 2026	a) The device shall bear the following identification marks on its body: i) Brand and model names ii) Temperature rating b) This letter supersedes our previous one of the same series dated 14.4.2019.
Fusible Link (1325)	"ACL" 68.33°C Fusible Link Standard Length (58mm) and Short Length (28mm) / Type/Model : Fusible Link / "ACL" 68.33°C a) Standard Length (58mm) b) Short Length (28mm) / Temperature Rating : 68.33°C	Dongguan Juwun Rubber & Plastic Products Co., Ltd.	10/11/2021	January 2025	a) For both sizes, they shall bear the following identification marks on their bodies: i) "ACL" Trade mark ii) Temperature grade of 68.33°C iii) Date code, Lot & Serial reference on one side b) For static loading up to 3 kg. c) This letter is subject to review by January 2025.

LIST OF PRODUCT APPROVED FOR USE IN VENTILATING SYSTEMS

Ventilation Systems Group of FIRE SERVICES DEPARTMENT

Note (1) : For details of the acceptance criteria / conditions , please refer to the FSD approval letter(s) issued to the manufacturer / authorized supplier(s) of the products

Note (2) : Please refer to FSD Circular Letter No. 1/2024 for guidance for application for approval of Fusible Link and Electrostatic Filter or Precipitator products. If the product has been listed and published by a Product Certification Body (PCB) and Product Certification, it is deemed to be accepted by the FSD subject to such product being in conforming with all local relevant local requirements on product specification and its application in ventilating systems. As stipulated under Chapter 123J - Building (Ventilating Systems) Regulations and Chapter 132CE - Ventilation of Scheduled Premises Regulation, fusible link and electrostatic filter or precipitator shall be of a type approved by the Director of Fire Services. In this connection, application for FSD approval on all fusible link and electrostatic filter or precipitator for use in ventilating systems is required.

TYPE	BRAND NAME / MODELS / DESCRIPTION	MANUFACTURER / AUTHORIZED SUPPLIER	FSD ACCEPTANCE DATE	DATE TO REVIEW (Subject to Renewal)	Remarks
Fusible Link (1350)	"ACL® 68.33°C" Fusible Link (HD) Type/Model : "ACL® 68.33°C" Fusible Link (HD) / Temperature Rating : 68.33°C	Dongguan Juwun Rubber & Plastic Products Co., Ltd.	29/3/2022	January 2027	a) The product shall bear the following identification marks on their bodies: i) Brand and model names ii) Temperature rating iii) Date of production code iv) Lot & serial code b) This letter supersedes our previous one of the same series dated 17.11.2017
Fusible Link (1365)	"KK 68.33°C" Fusible Link / Type/Model : "KK 68.33°C" Fusible Link a) Size : 50mm b) Size : 25mm / Temperature Rating : 68.33°C	Kam Kee Air-Conditional Engineering	20/5/2022	May 2027	a) For both sizes, they shall bear the following identification marks on their bodies: i) Brand and model names ii) Temperature rating iii) Batch identification (With an alphabet and a 2-digit figure standing for the batch number and the year of production respectively). b) This letter is subject to review by May 2027.
Fusible Link (1390)	"Globe" Model G Fusible Link / Model/Type : Model G 155°F (68°C) / Temperature Rating : Not exceeding 69°C / Product Certification : The product is "UL" listed under File JGIX.R1431. The fusible link shall maintain its status as "UL" listed products	GLOBE Technologies Corp., USA	11/8/2022	July 2027	a) The fusible link shall bear the following identification marks on its body: i) Brand name ii) Temperature rating mark of 155°F & iii) UL mark b) For loads from 3 to 45 lbs. inclusive c) Our previous letter of the same series dated 31.5.2018 are hereby supersede; and d) The assessment is subject to review in July 2027
Fusible Link (1393)	"Globe" model "G" 68°C Thermal Fusible Link for used in LASER 9010 & 9000 series Fire and Smoke Dampers / Model / Type : Model 'G', part # 315155, fusible link / Temperature Rating : 155°F (68°C) / Product Certification : The product is "UL" listed under File JGIX.R1431. The fusible link shall maintain its status as "UL" listed product	GLOBE Technologies Corporation, USA	17/8/2022	August 2027	a) The fusible link shall bear the following identification marks on its body: i) Brand and model names ii) Temperature rating & iii) UL mark b) The fusible link shall maintain its status as a "UL" listed product. c) This assessment is subject to review by August 2027.

LIST OF PRODUCT APPROVED FOR USE IN VENTILATING SYSTEMS

Ventilation Systems Group of FIRE SERVICES DEPARTMENT

Note (1) : For details of the acceptance criteria / conditions , please refer to the FSD approval letter(s) issued to the manufacturer / authorized supplier(s) of the products

Note (2) : Please refer to FSD Circular Letter No. 1/2024 for guidance for application for approval of Fusible Link and Electrostatic Filter or Precipitator products. If the product has been listed and published by a Product Certification Body (PCB) and Product Certification, it is deemed to be accepted by the FSD subject to such product being in conforming with all local relevant local requirements on product specification and its application in ventilating systems. As stipulated under Chapter 123J - Building (Ventilating Systems) Regulations and Chapter 132CE - Ventilation of Scheduled Premises Regulation, fusible link and electrostatic filter or precipitator shall be of a type approved by the Director of Fire Services. In this connection, application for FSD approval on all fusible link and electrostatic filter or precipitator for use in ventilating systems is required.

TYPE	BRAND NAME / MODELS / DESCRIPTION	MANUFACTURER / AUTHORIZED SUPPLIER	FSD ACCEPTANCE DATE	DATE TO REVIEW (Subject to Renewal)	Remarks
Fusible Link (1421)	"Globe" Model GS Fusible Link / Model/Type : Model GS / Temperature Rating : 68°C (155°F) / Product Certification : The product is "UL" listed under File JGIX.R1431. The fusible link shall maintain its status as "UL" listed product	Globe Technologies Corporation	2/2/2023	Jan 2028	a) For loads from 3 to 45 lbs inclusive. b) The fusible link shall bear the following identification marks on its body: i) Brand name ii) Temperature rating mark and iii) UL mark c) Our previous letter of same series dated 9.4.2021 is hereby superseded; and d) The assessment is subject to review in January 2028.
Fusible Link (1424)	"EVERTOP" SR Model ETL II Electro Thermal Link / Model/Type : EVERTOP SR Model ETL II / Temperature Rating : Not exceeding 69°C / Product Certification : The product is "UL" listed under File SZNT.R1431. The fusible link shall maintain its status as "UL" listed product / Quality Assurance Scheme : The manufacturer operates a quality management system to ISO 9001:2015 certified by DQS Inc. under Certificate No. 10001339 QM15 dated 18.5.2021.	GLOBE Technologies Corp., USA	6/2/2023	Jan 2028	a) The device shall bear the following identification marks on its body: i) Brand and model names ii) Temperature rating iii) UL mark b) For loads from 5 to 40 lbs. inclusive c) This letter supersedes our previous one of the same series dated 6.11.2018. d) This assessment is subject to review in January 2028 or with the updating of edition of the test standard.
Resettable Thermal Link (1431)	"PHL LINKS" Model 5720 Resettable Thermal Link (McCable Link) / Model/Type PHL LINKS Model 5720 / Temperature Rating : Not exceeding 69°C / Product Certification : The product is "UL" listed under File JGIX.R1431. The fusible link shall maintain its status as "UL" listed product	GLOBE Technologies Corp., USA	28/4/2023	April 2028	a) For loads end mount from 1 to 25 lbs. inclusive and side mount 1 to 4 lbs. inclusive b) This assessment is subject to review in April 2028 or with the updating of edition of the test standard.
Fusible Link (1474)	"TROX 0572 68C" Fusible Link / Type/Model : "TROX 0572 68C" Fusible Link / Temperature Rating : Not exceeding 69°C	TROX Malaysia Sdn. Bhd.	4/12/2023	November 2028	a) The product shall bear the following identification marks on their bodies: i) Brand and model names ii) Temperature rating b) This assessment is subject to review by November 2028.

LIST OF PRODUCT APPROVED FOR USE IN VENTILATING SYSTEMS

Ventilation Systems Group of FIRE SERVICES DEPARTMENT

Note (1) : For details of the acceptance criteria / conditions , please refer to the FSD approval letter(s) issued to the manufacturer / authorized supplier(s) of the products

Note (2) : Please refer to FSD Circular Letter No. 1/2024 for guidance for application for approval of Fusible Link and Electrostatic Filter or Precipitator products. If the product has been listed and published by a Product Certification Body (PCB) and Product Certification, it is deemed to be accepted by the FSD subject to such product being in conforming with all local relevant local requirements on product specification and its application in ventilating systems. As stipulated under Chapter 123J - Building (Ventilating Systems) Regulations and Chapter 132CE - Ventilation of Scheduled Premises Regulation, fusible link and electrostatic filter or precipitator shall be of a type approved by the Director of Fire Services. In this connection, application for FSD approval on all fusible link and electrostatic filter or precipitator for use in ventilating systems is required.

TYPE	BRAND NAME / MODELS / DESCRIPTION	MANUFACTURER / AUTHORIZED SUPPLIER	FSD ACCEPTANCE DATE	DATE TO REVIEW (Subject to Renewal)	Remarks
Fusible Link (1503)	"ACL [®] 68.33°C Fusible Link Standard Length (58mm) and Short Length (28mm) / Type/Model : Fusible Link / "ACL [®] 68.33°C a) Standard Length (58 mm) b) Short Length (28 mm) / Temperature Rating : 68.33°C	Dongguan Juwun Rubber & Plastic Products Co., Ltd., PRC	30/7/2024	August 2029	a) For both models, they shall bear the following identification marks on their bodies: i) "ACL [®] Trade mark ii) Temperature grade of 68.33°C on both sides iii) Date Code, Lot & Serial reference on one side b) For static loading up to 5kg c) This assessment supersedes our previous one of the same series dated 10.11.2021 d) This assessment is subject to review by August 2029