










**Common Fire Service Installations and Equipment and other products**  
**NOT Requiring FSD's Prior Acceptance**

- Abbreviations:
1. FSDCOP - [Codes of Practice for Minimum Fire Service Installations and Equipment and Inspection, Testing and Maintenance of Installations and Equipment by Fire Services Department](#)
  2. BDFS Code - [Code of Practice for Fire Safety in Buildings 2011 by Buildings Department](#)
  3. Wiring Code - [Code of Practice for the Electricity \(Wiring\) Regulations by Electrical and Mechanical Services Department](#)

	<b>Fire Service Installations and Equipment / Other Products</b> (Application for prior acceptance is not required)	<b>Requirements for compliance prior to installation/use and relevant information</b>
<b>1.</b>	<p><b>Emergency Lighting</b></p> 	<ol style="list-style-type: none"> <li>a) Conformity to requirements as stipulated in: <ol style="list-style-type: none"> <li>(i) FSDCOP (latest version)</li> <li>(ii) <a href="#">PPA 104 - Requirements for Emergency Lighting Systems (with Central Power Supply)</a></li> <li>(iii) <a href="#">PPA 104(A) - Requirements for Self-contained Luminaires Emergency Lighting Systems</a></li> <li>(iv) BDFS Code</li> <li>(v) Wiring Code</li> </ol> </li> <li>b) Submit the test certificate/report to respective sections of FSD (such as 'Fire Service Installations Division', respective 'Regional Office', etc.) during application for acceptance inspection/testing of fire service installations/equipment (such as in the course of application for general restaurant licence or application for Fire Services Certificate for new building)</li> <li>c) Present the test certificate/report to Inspecting Officer during FSD Inspection.</li> <li>d) For further enquiry, please contact: <p><b>Policy Division</b>  <b>Licensing and Certification Command</b>  <b>5/F, Fire Services Headquarters Building,</b>  <b>1 Hong Chong Road, Tsim Sha Tsui East,</b>  <b>Kowloon, Hong Kong</b></p> <p><b>Telephone: 2733 7660 Fax: 2367 3631</b></p> </li> </ol>

	<b>Fire Service Installations and Equipment / Other Products</b> <b>(Application for prior acceptance is not required)</b>	<b>Requirements for compliance prior to installation/use and relevant information</b>
2.	<b>Exit Sign</b> <b>(including Directional Sign)</b> 	a) Conformity to requirements as stipulated in: <ul style="list-style-type: none"> <li>(i) FSDCOP (latest version)</li> <li>(ii) BDFS Code</li> <li>(iii) Wiring Code</li> </ul> b) Submit the test certificate/report to respective sections of FSD (such as 'Fire Service Installations Division', respective 'Regional Office', etc.) during application for acceptance inspection/testing of fire service installations/equipment (such as in the course of application for general restaurant licence or application for Fire Services Certificate for new building)           c) Present the test certificate/report to Inspecting Officer during FSD Inspection.
3.	<b>Strobe Light NOT integrated with Alarm/Sounder and/or NOT in conjunction with Automatic Fire Alarm System</b> 	a) Conformity to requirements as stipulated in: <ul style="list-style-type: none"> <li>(i) FSDCOP (latest version)</li> <li>(ii) <a href="#">FSD Circular Letter No. 2/2012</a></li> <li>(iii) Wiring Code</li> </ul> b) Submit the test certificate/report to respective sections of FSD (such as 'Fire Service Installations Division', respective 'Regional Office', etc.) during application for acceptance inspection/testing of fire service installations/equipment (such as in the course of application for general restaurant licence or application for Fire Services Certificate for new building)           c) Present the test certificate/report to Inspecting Officer during FSD Inspection.

	<b>Fire Service Installations and Equipment / Other Products</b> <b>(Application for prior acceptance is not required)</b>	<b>Requirements for compliance prior to installation/use and relevant information</b>
<b>4.</b>	<b>Module for Automatic Fire Alarm System Monitor</b>  	a) Conformity to requirements as stipulated in: (i) FSDCOP (latest version) (ii) Wiring Code  b) Submit the test certificate/report to respective sections of FSD (such as 'Fire Service Installations Division', respective 'Regional Office', etc.) during application for acceptance inspection/testing of fire service installations/equipment (such as in the course of application for general restaurant licence or application for Fire Services Certificate for new building)  c) Present the test certificate/report to Inspecting Officer during FSD Inspection.
<b>5.</b>	<b>Smoke Stop Door</b>  	a) Conformity to requirements as stipulated in: (i) BDFS Code  b) Observe <a href="#">Section 15 of Fire Services (Fire Hazard Abatement) Regulation (Chapter 95F)</a>
<b>6.</b>	<b>Door Lock</b>  	a) Conformity to requirements as stipulated in: (i) BDFS Code  b) Observe <a href="#">Section 15 of Fire Services (Fire Hazard Abatement) Regulation (Chapter 95F)</a>

	<b>Fire Service Installations and Equipment / Other Products</b> <b>(Application for prior acceptance is not required)</b>	<b>Requirements for compliance prior to installation/use and relevant information</b>
7.	<b>Door Releasing Device NOT to be used in conjunction with Automatic Fire Alarm System</b>  	Conformity to requirements as stipulated in: <ul style="list-style-type: none"> <li>(i) BDFS Code</li> <li>(ii) Wiring Code</li> </ul> a) Observe <a href="#">Section 15 of Fire Services (Fire Hazard Abatement) Regulation (Chapter 95F)</a>
8.	<b>Fire/Smoke Seal for Smoke Stop Door</b>  	a) Conformity to requirements as stipulated in: <ul style="list-style-type: none"> <li>(i) BDFS Code</li> </ul>
9.	<b>Piping and associated fittings for Sprinkler system and Fire Hydrant/Hose reel system</b>  	a) Conformity to requirements as stipulated in: <ul style="list-style-type: none"> <li>(i) FSDCOP (latest version)</li> <li>(ii) <a href="#">FSD Circular Letter No. 3/2006</a></li> <li>(iii) <a href="#">FSD Circular Letter No. 3/2012</a></li> <li>(iv) <a href="#">Handbook on Plumbing Installation for Buildings issued by Water Supplies Department</a></li> </ul>

	<b>Fire Service Installations and Equipment / Other Products (Application for prior acceptance is not required)</b>	<b>Requirements for compliance prior to installation/use and relevant information</b>
<b>10.</b>	<b>Sand buckets</b>	a) Conformity to requirements as stipulated in: (i) FSDCOP (latest version)
<b>11.</b>	<b>Equipment and installation being used in Dangerous Goods Store or Dangerous Goods Vehicles (e.g. Vapour Recovery Monitoring System, equipment used in Petrol Filling Station, etc.) other than Liquid Dispensing Device and flammable Liquid Storage Tank</b>	b) Please submit relevant documents to Dangerous Goods Division of Fire Services Department during formal dangerous goods licensing application. c) For further enquiry, please contact:  <b>Dangerous Goods Division 4/F, Fire Services Department Kwai Chung Office Building, 86 Hing Shing Road, Kwai Chung, New Territories, Hong Kong.</b>  <b>Tel.: 2417 5757 Fax: 2413 0873</b>
<b>12.</b>	<b>Smoke mask</b>	-

Remarks:

The Fire Services Department (FSD) receives applications in respect of the fire service installations and equipment (FSI) and other products as mentioned in this list from time to time. Please note that application for prior acceptance in respect of these FSIs and products is not required. Registered Fire Service Installation Contractors and contractors for the installations of other equipment have the responsibilities to comply with the corresponding requirements as mentioned in the list. This list is by no means exhaustive. Further enquiries about application for approval/acceptance of FSI and other products can be made to the Fire Service Installations Division or the Investigation and Research Section of the Licensing and Certification Command, FSD.