

This document is for reference only. Detailed fire safety requirements will be separately issued subject to the result of on-site assessment.

本文件只供參考。詳細的消防安全規定會視乎現場評估的結果而另外發出。

Sample 3



FIRE SAFETY REQUIREMENTS FOR TIMBER STORE ON OPEN GROUND

在空曠地方開設木料倉的消防安全規定

1. Timber store shall be constructed and maintained in good and substantial repair and clean condition to the satisfaction of the Authority.
木料倉的建築及保養必須符合主管當局的規定。
2. Neither open fires nor any cooking shall be permitted in any timber store.
木料倉內不得設有明火；亦不得在倉內煮食。
3. No person, except watchman only not exceeding two in number, shall dwell in any timber store.
除不超過兩名看守人外，任何人均不得在倉內居住。
4. The licensee of any timber store shall install such fire service installations and equipment as required by the Authority and maintain them in efficient working order.
木料倉持牌人必須依照主管當局的規定裝設消防裝置或設備，並經常保持其性能良好。
5. Sufficient 'NO SMOKING' signs in 120mm English letters and Chinese characters shall be prominently displayed.
須將足夠的 120 毫米中英文“不准吸烟”告示懸掛於當眼位置。

This document is for reference only. Specific fire safety requirements will be issued subject to the result of on-site assessment.

本文件只供參考。詳細的消防安全規定會視乎現場評估的結果而另外發出。

This document is for reference only. Detailed fire safety requirements will be separately issued subject to the result of on-site assessment.

本文件只供參考。詳細的消防安全規定會視乎現場評估的結果而另外發出。

Sample 3

6. Where electric machinery is installed, the Commissioner for Labour shall be informed.
如設有電動機器，則必須向勞工處長呈報。
7. The timber store shall be surrounded by a fence of not less than 2m in height and constructed of non-combustible materials where the store is within 15m of any building.
如在任何建築物十五米範圍內，木料倉應以不易燃材料建築及不少過兩米高的圍牆環繞。
8. _____9-litre water type fire extinguisher(s) of approved models shall be provided.
木料倉內應裝設有認可類型的九升裝水式滅火筒 _____ 具。
9. All exits shall be kept free from obstruction.
所有出路必須保持暢通無阻。
10. All structures erected within the timber store shall be approved by the Buildings Department and constructed of non-combustible materials.
在木料倉範圍內的全部建築物，應得到屋宇署核准，並用不易燃材料築成。

This document is for reference only. Specific fire safety requirements will be issued subject to the result of on-site assessment.

本文件只供參考。詳細的消防安全規定會視乎現場評估的結果而另外發出。