

Fire Services Requirements  
for Computer Classroom

1. \_\_\_\_\_ CO<sub>2</sub> fire extinguisher(s) of not less than 4.5 kg of approved type shall be provided in the computer classroom.
2. All electric wirings supplying electricity to the computer shall be run in metal conduit and to be securely fixed on wall/floor.