

**This document is for reference only. Specific fire safety requirements will be issued subject to the result of on-site assessment.**

**本文件只供参考。详细的消防安全规定会视乎现场评估的结果而另行发出。**

**Sample 3**

**范本 3**



**FIRE SAFETY REQUIREMENTS FOR TIMBER STORE ON OPEN GROUND**

**设于露天地方的木料仓的消防安全规定**

1. Timber store shall be constructed and maintained in good and substantial repair and clean condition to the satisfaction of the Authority.  
木料仓的建造及保养，必须保持在妥善、维修充足及清洁干净的状况，以令消防处满意。
2. Neither open fires nor any cooking shall be permitted in any timber store.  
木料仓内不得有明火；亦不得在仓内煮食。
3. No person, except watchman only not exceeding two in number, shall dwell in any timber store.  
任何人均不得在仓内居住，看守员除外，但不得超过两人。
4. The licensee of any timber store shall install such fire service installations and equipment as required by the Authority and maintain them in efficient working order.  
木料仓持牌人必须依照消防处的规定装设消防装置或设备，并经常保持其操作性能良好。

**This document is for reference only. Specific fire safety requirements will be issued subject to the result of on-site assessment.**

**本文件只供参考。详细的消防安全规定会视乎现场评估的结果而另行发出。**

**This document is for reference only. Specific fire safety requirements will be issued subject to the result of on-site assessment.**

**本文件只供参考。详细的消防安全规定会视乎现场评估的结果而另行发出。**

**Sample 3**

**范本 3**

5. Sufficient 'NO SMOKING' signs in 120mm English letters and Chinese characters shall be prominently displayed.  
须将足够数量的中英文“不准吸烟”告示，悬挂于当眼位置，字体大小应为 120 毫米。
6. Where electric machinery is installed, the Commissioner for Labour shall be informed.  
如设有电动机，必须向劳工处处长呈报。
7. The timber store shall be surrounded by a fence of not less than 2m in height and constructed of non-combustible materials where the store is within 15m of any building.  
如木料仓所在位置与任何建筑物相距不足十五米，应采用不可燃物料建造不低过两米的围栏，以环绕仓库范围。
8. \_\_\_\_\_9-litre water type fire extinguisher(s) of approved models shall be provided.  
须设置认可类型的九公升装水式灭火筒 \_\_\_\_\_ 具。
9. All exits shall be kept free from obstruction.  
所有出口必须保持畅通无阻。
10. All structures erected within the timber store shall be approved by the Buildings Department and constructed of non-combustible materials.  
木料仓范围内的全部建筑物，必须得到屋宇署核准，并以不可燃物料建造。

**This document is for reference only. Specific fire safety requirements will be issued subject to the result of on-site assessment.**

**本文件只供参考。详细的消防安全规定会视乎现场评估的结果而另行发出。**