

消防處  
防火總區

香港九龍尖沙咀東部康莊道 1 號 5 樓  
消防總部大廈



**FIRE SERVICES DEPARTMENT  
FIRE PROTECTION COMMAND**

FIRE SERVICES HEADQUARTERS BUILDING,  
No. 1 Hong Chong Road, 5/F.,  
Tsim Sha Tsui East, Kowloon,  
Hong Kong

本處檔號 Our Ref.: (21) in FP 314/07 IV

來函檔號 Your Ref.:

電訊掛號 Telex: 39607 HKFSD

HX



(24 小時 Hours)

圖文傳真 Fax: 852-2723 2197

電話 Tel. No.:

5 March 1999

**FSD Circular Letter No. 3/99**  
**Certification of Fire Service Installations and Equipment**

In view of the technological development, revision of local design codes and international fire standards in recent years, the existing forms FSI/314 and FSI/314A used for certifying fire service installations and equipment in new buildings and minor addition and alteration projects have been revised to take into account of the above changes and suitably amended.

These new forms FSI/314 and FSI/314A will be put into use with immediate effect from the date of this circular letter. All Authorized Persons, Registered FSI Contractors are advised to carefully complete the form and submit it together with all required documents to Fire Protection Command, New Projects Division for the certification of fire service installations and equipment.

Signed  
(LAU Shu-lam)  
for Director of Fire Services

FSI/314

To : Director of Fire Services

Fire Service Installation Plans for Building at

\_\_\_\_\_  
\_\_\_\_\_

PART I

This is to certify that the attached fire service installation plans are identical to the building plans approved by you on \_\_\_\_\_ . Your file reference is FP 8/\_\_\_\_\_ .

Signed \_\_\_\_\_

Date \_\_\_\_\_

Full Name of Authorized Person \_\_\_\_\_

PART II

This is to certify that the details and specifications of all installations shown on the attached fire service installation plans are as prescribed by the Fire Services Department and in accordance with the relevant Rules and Codes of Practice as listed below:-

**Deleted.**  
**See FSD Circular Letter**  
**No. 1/2005**

- Rules of the Fire Officer's Committee for -
  - Automatic Sprinkler Installations (29th Edition)
  - Automatic Fire Alarm Installations (14th Edition)
  - Installation of External Drenchers (4th Edition)

Rules of the Loss Prevention Council for -  
Automatic Sprinkler Installations

- Codes of National Fire Protection Association for -
  - Carbon Dioxide Extinguishing Systems (Standard 12)
  - Clean Agent Fire Extinguishing Systems (Standard 2001)
  - Water Spray Fixed Systems for Fire Protection (Standard 15)

Codes of Practice for Minimum Fire Service Installations and Equipment,  
Fire Services Department

- Fire Alarm Systems
- Fire Hydrant/Hose Reel Systems

Others \_\_\_\_\_  
\_\_\_\_\_

Signed \_\_\_\_\_

Date \_\_\_\_\_

Full Name of FSI Contractor/Consultant \_\_\_\_\_

Correspondence Address \_\_\_\_\_

Tel No. \_\_\_\_\_

Mark "x" where applicable



**Deleted.**

**See FSD Circular Letter  
No. 1/2005**

FSI/314A

To : Director of Fire Services

Fire Service Installation Plans for Building at

\_\_\_\_\_  
\_\_\_\_\_

---

This is to certify that the details and specifications of all installations shown on the attached fire service installation plans are as prescribed by the Fire Services Department and in accordance with the relevant Rules and Codes of Practice as listed below:-

Rules of the Fire Offices' Committee for -

Automatic Sprinkler Installations (29<sup>th</sup> Edition)

Automatic Fire Alarm Installations (11<sup>th</sup>/12<sup>th</sup> Edition)

Installation of External Drenchers (4<sup>th</sup> Edition)

Rules of the Loss Prevention Council for -

Automatic Sprinkler Installations

Codes of National Fire Protection Association for -

Carbon Dioxide Extinguishing Systems (Standard 12)

Clean Agent Fire Extinguishing Systems (Standard 2001)

Water Spray Fixed Systems for Fire Protection (Standard 15)

Codes of Practice for Minimum Fire Service Installations and Equipment,  
Fire Services Department

Fire Alarm Systems

Fire Hydrant/Hose Reel Systems

Others \_\_\_\_\_

\_\_\_\_\_

---

Signed \_\_\_\_\_

Date \_\_\_\_\_

Full Name of FSI Contractor/Consultant \_\_\_\_\_

Correspondence Address \_\_\_\_\_

Tel No. \_\_\_\_\_

Mark “x” where applicable