

消防處  
防火總區

香港九龍尖沙咀東部康莊道1號5樓  
消防總部大廈



**FIRE SERVICES DEPARTMENT  
FIRE PROTECTION COMMAND**

FIRE SERVICES HEADQUARTERS BUILDING,  
No. 1 Hong Chong Road, 5/F.,  
Tsim Sha Tsui East, Kowloon,  
Hong Kong

本處檔號 Our Ref.: (3) in FP(FS) 314/07

來函檔號 Your Ref.:

電訊掛號 Telex: 39607 HKFSD

HX



(24小時 Hours)

圖文傳真 Fax: 852-2723 2197

電話 Tel. No.:

15 December 1999

**Fire Services Department Circular Letter No. 7/99**  
**Installation and Maintenance of Audio/Visual Advisory System,**  
**Emergency Generator, Emergency Lighting and Exit Sign**

The captioned works are classified as fire service installations and equipment. Please be reminded that according to the Fire Service (Installations and Equipment) Regulations no fire service installation or equipment shall be installed, maintained, inspected and repaired by any person other than a registered fire service installation contractor. Any person who contravenes the provisions of these Regulations shall be guilty of an offence and shall be liable on conviction to a fine of \$5,000.-

You are advised to take note of the contents of this Circular Letter when drawing up your construction and maintenance contracts for the captioned works.

Signed  
(LEE Chee-chung)  
for Director of Fire Services