

消防處
防火總區

香港九龍尖沙咀東部康莊道 1 號 5 樓
消防總部大廈



**FIRE SERVICES DEPARTMENT
FIRE PROTECTION COMMAND**

FIRE SERVICES HEADQUARTERS BUILDING,
No. 1 Hong Chong Road, 5/F.,
Tsim Sha Tsui East, Kowloon,
Hong Kong

本處檔號 Our Ref.: (5) in FP 314/07 IV

來函檔號 Your Ref.:

電訊掛號 Telex: 39607 HKFSD

HX

}
(24 小時 Hours)

圖文傳真 Fax: 852-2723 2197

電話 Tel. No.:

5 August 1997

F.S.D. Circular Letter No. 8/97
Specification for Portable Fire Extinguishers

Subsequent to the withdrawal of the BS 5423: 1987 'Specification for Portable Fire Extinguishers' which was replaced by BS EN3: Part 1 to 6 on 1.1.1997, this Department now accepts test reports for the testing of fire extinguishers in accordance with BS EN3: Part 1 to 6.

This Department will also continue to accept test reports for the testing of fire extinguishers in accordance with BS 5423: 1987 provided that the test reports are within 10 years from the date of issue.

Signed
(HSU King-ping)
for Director of Fire Services