

**Fire Safety Requirements / Recommendations
for
Religious Ceremony in Temporary Structures**

1. Portable fire fighting equipment of the approved type shall be provided as follows:
 - 1.1 _____ x 9 L water type fire extinguisher(s) at _____ ; and
 - 1.2 _____ x 4.5 kg CO₂ type fire extinguisher(s) at _____.
2. Metal incinerator shall be provided for burning joss paper.
3. No naked flame is permitted within 6 m of the premises other than lighted joss sticks.
4. If the structure is to be roofed over and covered at sides, metal sheets shall be used.
5. No seats shall be provided for the audience/worshippers.
6. Additional Recommendations (if any) : -

(Rev. 7/2024)