SCH/104



FIRE SERVICES DEPARTMENT Fire Safety Requirements for

Design & Technology / Art Room

| 1. | Portable fire-fighting equipment of the approved type, over and above those installed for the occupation of the building, shall be provided as follows: |
|----|--|
| | 1.1x 9 L water type fire extinguisher(s) at; |
| | 1.2 x 4.5 kg CO2 type fire extinguisher(s) at ; and |
| | 1.3 x 1.44 m2 fire blanket at |
| 2. | The room shall be completely separated from other part of the premises by walls with a minimum |
| | fire resistance rating of 60 minutes. High level ventilation to open-sided corridor/balcony at a height of 1800 mm from floor level may be provided. |
| 3. | Windows or wall openings giving onto corridors and staircases shall be fitted with wired glazing in fixed metal frames. |
| 4. | All exit doors of the room shall be self-closing with a minimum fire resistance rating of 60 minutes. |
| 5. | Spray painting involving the use of flammable liquids, except aerosol spray painting, is not permitted inside the room or any other part of the school premises. |
| 6. | When wax melting is required, it should be heated indirectly over a hot bath. |
| 7. | No mixed activities involving heat, paint spraying and wax melting etc. should be conducted at the same time. |
| 8. | No storage or use of Dangerous Goods (DG) in excess of the respective general exempt quantity (GEQ) within the meaning of the Dangerous Goods (Application and Exemption) Regulation |

2012, Chapter 295E, Laws of Hong Kong is permitted without a licence granted by the Director of

Rev. (4/2024)

9.

Fire Services.

Additional Requirements (if any): -