

Summary of Notes of 47th Ventilation Installations Liaison Group Meeting

(held on 25.2.2016)

1.	<p><u>Electrical Interlock and VAC Control System for Licensed Premises</u></p> <p>The Chairman advised that a Sub-working Group (SWG) meeting was held on 29 October 2015. Notes of meeting was being prepared and would be issued soon.</p>
2.	<p><u>Advisory Letters to Building Owners/ Management Companies</u></p> <p>The Chairman informed members that advisory letters had been issued to incorporated owners / management companies of some of the identified buildings with Residential Care Home (RCH) and buildings with Child Care Centre (CCC) in December 2015 and February 2016. Mr. Isaac CHAN advised that this exercise would be continued to cover other buildings identified in the Risk Assessment Report endorsed by the management of FSD.</p>
3.	<p><u>AOB</u></p> <p><u>Use of Pre-insulated Panels for the Construction of Air Ducts in Mechanical Ventilating System</u></p> <p>The Chairman reported that the initial trial period of two year under FSD Circular Letter No. 1/2014 would be expired in October 2016. As acceptance of the material was still pending the re-submissions of test reports for compliance to BS EN 13403, the Chairman would seek the view of FSD's management in extending the trial period for another two years.</p>