

TEL NO:

OUR REF:

YOUR REF:

NOTE: NUMBER AND DATE SHOULD
BE QUOTED IN REFERENCE
TO THIS LETTER.



FIRE SERVICES DEPARTMENT.
EX HOWE BLOCK,
QUEENSWAY,
HONG KONG.

FIRE PREVENTION BUREAU
HELP US TO HELP YOU

P.O. Box 20192
Hong Kong.

16th April, 1971.

Circular No. AC 2/71

Dear Sir,

In view of the trend towards metrication and the availability of mild steel sheet in metric sizes, it has been decided to permit the use of standard sizes for the construction of fire dampers and associated assemblies.

My circular dated 28th May, 1968 refers. Where the figures 0.25" and 0.125" appear these may now be substituted, if you wish, by the figures 6 mm and 3 mm respectively.

I look forward to your continued support.

Yours faithfully,

(J.R.S. Pickett)
for Director of Fire Services

To: A/C Contractors Assn.,
Consultants & Contractors

JRSP/mk